



Waste Hauler List

This list is provided to FOG Producing Establishments only as a convenience, and does not imply an endorsement of the services provided by any of the listed companies. The City of Panama City makes no claim or representation, explicit or implied, regarding the performance of the following service providers. The City of Panama City encourage FOG Producing Establishments to exercise due diligence when hiring a pumping and/or waste hauler contractor. This list is based on information available at the time and may not include every company offering such service. The vendors are listed alphabetically.

Company	Phone #
Birmingham Hide and Tallow Co.	(205)252-1197
DAR Pro Solutions	(888)957-7645
Environmental Grease Solutions	(850)691-6347
Gulf Coast Grease	(850)596-9547
Hulls Environmental Services	(850)890-1602
Liquid Environmental Solutions	(214)492-5145
Parker Septic	(850)215-5860
Roto- Rooter Plumbing	(850)769-3666
Xtreme Plumbing and Septic	(850)999-7800

Sec. 23-512 – Gravity Grease Interceptor Cleaning and Maintenance Requirements

(a) Partial pump of interceptor contents or on-site pump and treatment of interceptor contents will not be allowed due to reintroduction of fats, oils, and grease to the interceptor. In no way shall the pumped material be returned to any private or public portion of the sanitary sewer collection system. All grease waste haulers and procedures for pumping grease interceptors shall comply with the City of Panama City Chapter 23, Article IX – Fats, Oil and Grease Control Ordinance.

(b) Gravity grease interceptors must be pumped in full (total pump of all contents) when the total accumulations of surface FOG reaches 6"(including floating solids) and settled solids reaches 8" and or when solids reach twenty-five percent (25%) of the grease interceptor's inlet liquid depth. This criterion is referred to as the "25 Percent Rule". At no time shall the cleaning frequency exceed 90 days unless approved in writing by the City. Failure to meet these requirements shall result in enforcement action. Approval will be granted on a case by case situation with submittal by the FPE documenting proof that a reduced cleaning frequency will meet the requirements of this FOG Ordinance. Some FPEs may need to consider a more frequent pumping schedule to meet this requirement. A City approved manifest of gravity grease interceptor cleaning/maintenance, and an FPE gravity grease interceptor self-monitoring checklist shall be maintained onsite at the FPE and provided to the City upon request. These documents need to be provided to the City for review before consideration for approval can be granted for a cleaning frequency to exceed 90 days.

501 Harrison Ave. Panama City, Florida 32401 850-872-3194 email;

FORM#1915 fog@panamacity.gov
Rev. 06/09/25